

# CASALI® WATERPROOFING SYSTEMS

DRAWING DETAIL:  
CT-5-0002A

DRAWN BY:  
HAYDEN L.

DATE:  
20/01/2016

## METAL ROOF - GUTTER PARAPET

SCALE:  
NTS

VERIFIED BY:  
DOUG J.

VERSION:  
1.0

**NOTE:**

- MINIMUM GUTTER WIDTH OF 300mm AND FREEBOARD REQUIREMENT OF 50mm REFER TO NZBC E2/AS1 FIGURE 64c.
- MINIMUM AREA TO BE 4000m<sup>2</sup> AS PER NZBC E2/AS1 PARAGRAPH 5.1.4.
- MINIMUM GUTTER SLOPE TO BE 1:100 AS PER NZBC E2/AS1 PARAGRAPH 8.1.6.1.

